



**OFFICE OF THE GENERAL MANAGER ,  
WATCO DIVISION , CUTTACK.**

Phone/FAX No.: 0671-2547115, E.Mail : gmwatcoct@gmail.com

No. 5484 /Dt. 10-9-2013

To


M/S Laxmi Infra Venture PVT. LTD ✓  
Plot No:- 1390,1380/3003,1380/3004,1380/3031,1380/3030  
Mouza:- Nuahat,  
Dist:- Cuttack.

Sub:- Issue of NOC for Water Supply and sewerage connection to approval of proposed 4 blocks of B+25+21 residential apartment and G+2 storied Community hall, 1 Block of S+14 multi storied residential apartment, One Block of B+G+3 storied commercial building over Revenue Plot No. 1390,1380/3003,1380/3004,1380/3031,1380/3030 Under Mouza-Nuahat, Cuttack in favour of Sri Baman Charan Swain represented through GPA Holder Sri Rajesh Kumar Nayak, Mnaging Director of M/S Laxmi Infra Venture PVT. LTD

This Department has no Objection to have your own water supply and sewerage disposal system in the vicinity of your proposed 4 block of B+25+21 residential apartment and G+2 storied Community hall, 1 Block of S+14 multi storied residential apartment, One Block of B+G+3 storied commercial building over plot no. mentioned above as it is not possible to provide Water Supply from existing system and no sewerage system of WATCO at present in the vicinity of your above project site. However, when the public water supply and sewerage system of WATCO will be available adjacent to your proposed project site in future, you should avail both the facilities by making payment towards scrutiny and security fees required for water supply and sewerage connection as per the Odisha Water Works (Urban Local Body) Rule 1980 as amended from time to time. The No Objection Certificate for own water supply and sewerage disposal system is issued subject to fulfillment of the following conditions.

- 1) You should take permission from Central ground Water Authority / Central Ground Water Board / Water Reource Deptt. for abstraction of ground water for drin king / domestic purposes.
- 2) After getting approval from CDA and having own W/S arrangement, you should get the W/S samples tested in any Govt. Approved laboratory for potability of water and submit the authenticated test report on every quarter to the concerned Assistant Engineer of WATCO of the locality.
- 3) The treated effluent quality of sewerage shall confirm to the effluent standard stipulated by the State / Central Pollution Control Board & relevant B.I.S specification.
- 4) Under no circumstances effluent of septic tank is to be discharged in to the existing natural Nallah / water body. You should construct a captive Sewerage Treatment Plant of minimum liquid treatment capacity of 27.0 cum/ day as per the requirement stipulated in CPHEEO manual.
- 5) You should / also ensure that under no circumstance the environment is polluted due to non functioning/ under performance of your sewerage system.
- 6) Non-compliance to the above conditions as well as deviation to the undertaking furnished in the form of affidavit shall make you liable for action by the competent authority as per existing laws/ rules of Govt. Statutory authority.

Yours faithfully,


  
General Manager,  
WATCO Division, Cuttack.

R.K.  
10.9.23

80  
10/9/23


Memo No. 5485 /Dt. 10.4.2023


Copy Submitted to the Planning Member, Cuttack Development Authority (CDA), Cuttack for information. The building plan may please be approved only after submission of the detailed design & drawing of sewerage treatment plant & sewerage system of desired capacity.

  
General Manager,  
WATCO Division, Cuttack

Memo No. 5486 /Dt. 10.4.2023


Copy forwarded to the City Engineer, Cuttack Municipal Corporation, Cuttack for information.


K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

Memo No. 5487 /Dt. 10.4.2023


Copy forwarded to the Sr. Environment Engineer. State Pollution Control Board A/118, Parivesh Bhawan. Nilakantha Nagar, Bhubaneswar &, necessary action.


K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

Memo No. 5488 /Dt. 10.4.2023


Copy forwarded to the Sr. Nodal Officer of CGWA in Central Ground Water Board. Bhujal Bhawan,, Bhubaneswar-751001 for kind information &, necessary action.


K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

Memo No. 5489 /Dt. 10.4.2023

Copy forwarded to the Superintending Engineer., Irrigation Division, Cuttack for information &, necessary action.


K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

Memo No. 5490 /Dt. 10.4.2023


Copy submitted to the Chief Operating Officer / Chief Executive Office, WATCO, Bhubaneswar for favour of kind information.


K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

Memo No. 5491 /Dt. 10.4.2023

Copy to the Manager WATCO Sub-Division, Mahanadivihar, Cuttack for information with reference to Letter No. 409 Dt.22.03.2023.

K.K.  
10.4.23  


  
General Manager,  
WATCO Division, Cuttack

K.K.  
10.4.23  
