



**OFFICE OF THE FIRE OFFICER,  
NORTHERN RANGE, SAMBALPUR**

Phone- 0663-2546050, Fax- 0663-2546056, E-mail- fonr-sbp@gov.in

No. G-169-2020/ 8935 /NR (FPW)

Dtd. 08/12/2020

To

Sri Bhabani Prasad Pany,  
Associates Infra Developer Pvt. Ltd,  
At-Bishops House, Ainthapali  
Dist- Sambalpur- 768004.

Sub: - Issuance of Fire and Life Safety measures in respect of Proposed S+4 Storied Residential Apartment Building (Block - A & B), over Plot No. 3123/4838 & others, Khata No. 433 /882 & others , Mouza- Sambalpur Town, Unit No. 12, Remed, Dist- Sambalpur.

\*\*\*\*\*

Sir,

With reference to the subject cited above this is to intimate that as per Odisha Fire Prevention and Fire Safety Rules, 2017 and Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019, Residential buildings (other than Hotels, Lodgings & Guest Houses), having a height of 15 mtrs and above require Fire Safety Recommendation. As shown in the plan this building is less than 15 mtrs height, hence, no Fire Safety Recommendation is required. However, you are advised to install Hose Reel hose, Fire extinguishers, 5,000 ltrs capacity terrace tank and 450 ltrs/min capacity terrace pump in the building for Fire Safety as per the NBCI-2016 and intimate the Assistant Fire Officer, Sambalpur Fire Station.

Yours Faithfully

  
08-12-20  
Fire Officer  
Northern Range, Sambalpur  
Fire Officer,  
Northern Range, Sambalpur