

**CENTRAL ELECTRICITY SUPPLY UTILITY OF ORISSA
OFFICE OF THE EXECUTIVE ENGINEER (ELECT)
CUTTACK ELECTRICAL DIVISION, JOBRA, CUTTACK.**

CESU/CED/TECH/No. 4623 / Dt. 30.5.18

To
M/S-Grand Bazar Developers LLP,
Opposite of Ramadevbaba Temple,
At-Nuahat, P.O-Phulanakhara, Dist-Cuttack.

Sub:- Permission for construction of 33KV lines & Sub-station for power supply to 6.5MVA load in phase manner (1st phase-2.0MVA with immediate effect till March-2019 & 2nd phase-Additional 4.5MVA (2.0MVA Commercial + 2.5MVA Domestic) from April-2019 to M/S Grand Bazar Developer LLP, At-Nuahat, opposite of Baba Ramdev Temple, Phulnakhara, Dist-Cuttack under Electrical Section Balikuda in 6% deposit Work Scheme.

Ref: - 1) Memo No. 12497 (2) dt.25.05.2018 of the C.G.M (Tech), CESU, Bhubaneswar.
2) Lr No 1559 dtd. 26.05.2018 of the S.E, E.C, Cuttack.

Sir,

With reference to the subject cited above, you are requested to deposit the following amount for construction of 33KV lines & Sub-station for power supply to 6.5MVA load in phase manner (1st phase-2.0MVA with immediate effect till March-2019 & 2nd phase-Additional 4.5MVA (2.0MVA Commercial + 2.5MVA Domestic) from April-2019 to M/S Grand Bazar Developer LLP, At-Nuahat, opposite of Baba Ramdev Temple, Phulnakhara, Dist-Cuttack under Electrical Section Balikuda in 6% deposit Work Scheme

Sl No	Name of the Work	S.Est.No / Dt & Amount / Scheme.	6% Super-vision Charges (Rs)	CESS 1% of Gross Amount (Rs)	Scope of work
1	Permission for construction of 33KV lines & Sub-station for power supply to 6.5MVA load in phase manner (1 st phase-2.0MVA with immediate effect till March-2019 & 2 nd phase-Additional 4.5MVA (2.0MVA Commercial + 2.5MVA Domestic) from April-2019 to M/S Grand Bazar Developer LLP, At-Nuahat, opposite of Baba Ramdev Temple, Phulnakhara, Dist-Cuttack.	28 / 2018-19 of CG.M (Tech), CESU, Bhubaneswar Rs.5,28,273/- (G) Rs 30,06,865/- (N) Rs.5,28,273/- (1% Cess) T & D (Dep.) 6 % Work.	30,06,865/-	5,28,273/-	1. Augmentation of 33KV Line-8.5Km with all other accessories. 2. Construction of new 33KV Line-5.0Km, 3. Construction of 33KV Line DP Str. on existing 33KV line-2Nos, 4. Construction of 33KV Line DP Str. for domestic line-1No. 5. Construction of 4Pole Str.-1No for commercial line, 6. Construction of main MU DP Str.-1 No for commercial load 7. Laying of 33KV XLPE UG cable-0.15Km for Road crossing near at M/S Grand Bazar Developer LLP in HDD system, 8. Construction of 4Pole Str.-1No for installation of 2x2MVA S/S, 9. Laying of 33KV XLPE UG cable-0.30KM for installation of 2x1MVA+1x500KVA S/S, 10. Construction of 4Pole Str.-1No for 2.5MVA domestic load, 11. (A) Additional 33KV bay & (B) Installation of 33KV out door VCB at 33/11KB S/S Balikuda-1No) 12. Installation of 33KV VCB with Control panel-5nos. 13. Laying of 300 mm ² 3 1/2 core PVC unarmoured cable by OPEN trench method Transformer Distribution box to Building LT panel. (All the above works are to be executed by the party out of which SL No. 7 to 10, 13 & 14 above are to be maintained by party on 6% deposit scheme)

The above work shall be executed by party after deposit of 6% supervision charge amounting to Rs 30,06,865.00 against sanction estimate No. 28/18-19 with CESU. The said amount may please be deposited in shape of Cash or Bank Draft in favour of (Manager(Elect), CESU C E D, Cuttack) payable at Cuttack. The terms and conditions for availing above power supply is as follows. -

Grand Bazar Developers LLP.

Contd. 02

(Signature)

TERMS AND CONDITIONS.

- 1) The CESS of 1% gross amount i.e. Rs. 5,28,273.00 & Inspection Fees will be deposited by the party respectively before the appropriate authority & submit the copies of the money receipts challan with the supply engineer before charging.
- 2) The lines will be constructed by the party through a HT Licensed Contractor as per REC standard & the original money receipt of the purchase of materials will be verified by the Supply Engineer.
- 3) All statutory requirements from the competent authority of different concerned departments must be obtained before power supply.
- 4) The lines & S/S will be charged only after on deposit of inspection fees and inspection of the lines by the Inspector, Govt. of Orissa and handed over to CESU for maintenance.
- 5) The quality of materials and standard of construction should be verified / supervised meticulously before handing over the lines to CESU. If any substandard quality will be noticed will attract disciplinary action on the concerned officer-in-charge.
- 6) The GTP of the major materials like Transformers, 300mm² XLPE UG cable, 148mm² & 100mm² AAAC, V-Poles, Hard Ware fittings, AB Switch, VCBs and other materials to be utilized for the work are to be submitted after due verification by E & MR of CESU to this Office for approval at this end and then those materials tested at the factory site of the manufacture by the representative of CESU prior to the installation at proposed site of the applicant. In no circumstances the materials shall be used at site without pre-depart inspection at factory site of manufacturer.
- 7) All the materials are to be procured from approved vendor as per CESU specification.
- 8) The necessary drawing may be approved by Supply Engineer before execution of the work.
- 9) The R.O.W problem is to be solved by party at its own arrangement.
- 10) The vendor selected to execute the work should be approved by the supply Engineer.
- 11) Any other modification/alternation for the above estimate will be intimated later & the differential amount will be paid by the party.
- 12) The safety aspects of the system at the time of work execution shall be strictly observed in compliance with regulation 3, 12, 14, 15, 19, 27, 29, 33, 43, 44 & 46 of CEA (measures relating to safety & Electric supply Regulation-2010 as amended till date).
- 13) The cost of the estimate is valid upto 31.03.2019. The estimate is subject to revise after 31.03.2019 if the party fails to deposit the supervision charge along with 1% CESS charges.
- 14) An undertaking is to be collected from the party to share the over drawal penalty charges if any levied by GRIDCO to CESU with response to para 315 & 316 of BSF order 2018-19 if drawal by the consumer exceeds 2000KVA.
- 15) The 33/0.4KV (2x1MVA + 1x0.5MVA) substation meant for domestic supply shall be charged after completion of construction activities of all domestic flats.
- 16) The existing 11KV line is to be dismantled prior to charging of the 33KV line.

All other departmental formalities of CESU should be observed before energisation of the said line.
S/s.

Encl:- Estimate Copy

Memo No. 4624 / Dt. 30.5.18
Copy submitted to the C.G.M (Tech), CESU, Bhubaneswar for favour of kind information

Memo No. 4625 / Dt. 30.5.18
Copy submitted to the Superintending Engineer, Electrical Circle, Cuttack for favour of kind information

Memo No. 4626 / Dt. 30.5.18
Copy to the Divisional Manager (Elect), E & MR, Division, Badambadi, Cuttack for information and necessary action.

Memo No. 4627 / Dt. 30.5.18
Copy to the S.D.O (Elect), Gopalpur / J.M (Elect), Balikuda for information & necessary action. They are requested for day to day supervision of works & also submit the completion certificate after completion of construction work.

Memo No. 4628 / Dt. 30.5.18
Copy to AM(F) under this division for information

Grand Bazar Developers LLP.

Authorised Signatory

Yours Faithfully,

A.G.M (Elect)
C.E.D. Cuttack

A.G.M (Elect)

A.G.M (Elect)

A.G.M (Elect)

A.G.M (Elect)

A.G.M (Elect)

138660 0000020000 000476 16

INSTRUMENTS FOR ₹ 1,50,000 & ABOVE ARE NOT VALID UNLESS SIGNED BY TWO OFFICERS

VALID FOR 3 MONTHS ONLY

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9

भारतीय स्टेट बैंक
STATE BANK OF INDIA
 अदाकर्ता शाखा / DRAWEE BRANCH: CUTTACK
 कोड नं. / CODE No: 00059

अधिकृत प्रबंधक
Brojo Bondhu Patnaik
 AUTHORIZED SIGNATORY
 शाखा प्रबंधक
 BRANCH MANAGER

00476138660 Key: SOGKUR Sr. No: 638805

528273.00 ₹ अदा करें

Five Lakh Twenty Eight Thousand Two Hundred and Seventy Three Only

ON DEMAND PAY

Key: SOGKUR Sr. No: 638805

DEMAND DRAFT

भारतीय स्टेट बैंक
State Bank of India
 शाखा प्रबंधक
 BRANCH MANAGER
 कोड नं. / CODE No: 00041
 574-2530894

भारतीय स्टेट बैंक
State Bank of India
 शाखा प्रबंधक
 BRANCH MANAGER
 कोड नं. / CODE No: 00041
 574-2530894

DEMAND DRAFT

Key: WUDJUY Sr. No: 863109

13082011
 D D M M Y Y Y

मांगे जानेपर MANAGER (ELECT.), CESU, C.E.D. CUTTACK

ON DEMAND PAY

रुपये RUPEES Thirty Lakh Six Thousand Eight Hundred and Sixty Five Only

101 000476138661 Key: WUDJUY

Sr. No: 863109

AMOUNT BELOW 3000000 (3/7)

3006865.00 ₹ अदा करें



भारतीय स्टेट बैंक
STATE BANK OF INDIA
 अदाकर्ता शाखा / DRAWEE BRANCH: CUTTACK
 कोड नं. / CODE No: 00059

अधिकृत प्रबंधक
Brojo Bondhu Patnaik
 AUTHORIZED SIGNATORY
 शाखा प्रबंधक
 BRANCH MANAGER

INSTRUMENTS FOR ₹ 1,50,000 & ABOVE ARE NOT VALID UNLESS SIGNED BY TWO OFFICERS

138660 0000020000 000476 16

Grand Bazar Developers LLP
 Authorised Signatory