

TPSODL

OFFICE OF THE EXECUTIVE ENGINEER
BERHAMPUR ELECTRICAL DIVISION NO-III, BERHAMPUR
BIDYUTPURI COLONY, BERHAMPUR-760010(GANJAM)
PH: 0680-2290071, E-mail: ee.bed3@southoodisha.com

No. T/1924 (6)

Dated 23/08/2021

To,
Sri Santosh Kumar Tripathy,
At-Govinda Vihar Main Road
(Infront of Ruby Eye Hospital),
Dist.-Ganjam, Odisha

Sub: - Permission for providing power supply to 3-ph. power supply to Residential Apartment at Govinda Vihar Main Road (Infront of Ruby Eye Hospital) for (16x03 KW) 48 Load with Common Area Load 08 KW on 400Volt on Commercial Tariff under Electrical Section, Lochapada on 6% Deposit Norm.

Ref :- 1-Lr. No.461 Dt-13.08.2021 of S.D.O., Electrical Sub Division, NO.IV.

Sir,

With reference to your application, you are here by permitted for power supply to 3-Ph. 3-ph. power supply to Residential Apartment at Govinda Vihar Main Road (Infront of Ruby Eye Hospital) for (16x03 KW) 48 Load with Common Area Load 08 KW on 400Volt on Commercial Tariff under Electrical Section, Lochapada on 6% Deposit Norm with the following terms and conditions.

Scope of Work :-

1-3-ph. Service Connection-01 no.(15 Mtr.).

Terms & Conditions :-

1. The above power supply shall be given at 400 Volt supply from the existing 500KVA,11/4 KV Govinda Vihar Main Road (Near Ruby Eye Hospital) S/S (TPSODL S/S) and the energy metering will be done at LT side with observing departmental formalities.
2. Right of way is sole responsibility of the applicant as per clause - 8 of OERC distribution (Condition of supply) code - 2004 and TPSODL shall not be held responsible if any disputes arise on right way problem during erection of work and thereafter too.
3. Specification laid down in relevant sections of I.E. Rules-2005 should be strictly followed during construction of line and sub-station work.
4. The load should not increase more than 08 KW .
5. The estimate is sanctioned for an amount of Rs-91,715/-(Rupees Ninety One Thousand Seven Hundred Fifteen) only out of which, applicant has to deposit of Rs.19,279/- (Rupees Nineteen Thousand Two Hundred Seventy Nine) only as per Sanctioned Estimate No.58/2021-22 Dt.23/08/2021 of this office towards 6% supervision charges of service connection estimate and including cost of 20-100 Amp W/C meter with Box and Modem ECD 210 & Communicating cord only including GST@18%.
(Copy of sanctioned estimate is enclosed herewith for reference)
6. Applicant has to deposit in shape of Bank draft infavour of the "TPSODL , BED-III, TATKAL ACCOUNT", Payable at-Berhampur or make payment through online through RTGS/NEFT in A/C No.625901010050076, IFSC Code-UBIN0562599, UNION BANK OF INDIA, KOMAPALLI.

7. Total Security Deposit of Rs: 26,166 /- (Rupees ^{Twenty Six Thousand one} ~~Hundred~~ ^{and Sixty} ~~Two~~) only is to be deposited and Tariff applicable in the ^(CPLT) Tariff and an agreement has to be executed by the applicant with the undersigned in the standard forms published by OERC observing all the departmental formalities in non-judicial stamp paper of worth Rs. 10/- each. Two sets of agreement papers are to be arranged by him along with following required documents during execution of agreement.
- Photostat copy of the registered document of the land / lease deed duly attested should be submitted in support of ownership of the premises/ land and any of the documents as may be required depending upon the nature of the unit to be produced.
 - No Objection Certificate from the Sarpanch /Gram Panchayat/NAC/Land development authority / land owing agency as the case may be, if required during charging of line.
 - Necessary undertaking by court affidavit is to be submitted by the applicant as the case may be, if required.
 - Photo copy of the income tax PAN Number issued by the Income Tax Commissioner and Photo copy of Adhar card and any photo Identity issue by the Govt. Office.
 - Three nos. of pass port size photograph duly attested by a gazette Officer.
 - Photo copy of the deposit particulars.
 - 2 (Two) nos. of known person should be accompanied for witness.
 - Valid proof against authorized representative or desingnated officer for execution of agreement.
8. Suitable Shunt capacitor must be connected at the load end to maintain the power factor as per the OERC norms.
9. The applicant should install the star / delta starter strictly for the motors in order to limit the starting current.
10. **The party has to produce the authenticity certificate of the person concerned at the time of execution of the agreement with the undersigned.**
- All the newly erected lines, electrical installations must be inspected by the Inspection Authority after due remittance of the inspection fees.
 - The applicant has to abide by the OERC condition of supply.
 - The applicant has to furnish the Inspection report of the total new line erected if any and the MV inspection of the internal electrification work along with the copies of purchase vouchers of major materials utilized in this work to the undersigned for verification and record, before charging.
 - The permission and the estimate are valid for 90 days only.**
 - The power supply has to be given after observing all departmental formalities.**

The approved route alignments drawing along with the sanctioned estimate are enclosed herewith for your information for availing power supply early. **All dues of the existing single phase consumer No.343203240537 is to be cleared up and M/R to be produced and should be dismantled before charging of the above new three-phase.**

Encl: As above.

Yours faithfully,


Executive Engineer (Elect.)
BED-III, Berhampur

CC to: -

- Asst. Manager(Elect.), Electrical Section, Lochapada for information & necessary action.
- S.D.O (Elect.) Electrical Sub- Division, No.IV for information & necessary action. **He is requested to clear up all dues of the existing single phase consumer No. 343203240537 and should be dismantled before charging of the above new three-phase.**
- Superintending Engineer(Elect.), City Circle, Berhampur.
- Revenue Section / Cash Section of this Division.