



CENTRAL ELECTRICITY SUPPLY UTILITY OF ODISHA .  
O/O - THE EXECUTIVE ENGINEER (ELECT.), B.E.D., BHUBANESWAR.  
PH: (95-674) 2587024 / 2587025 FAX: (95-674) 2587024

BED/TECH/ No. 11068 Dt. 18.12.19

To

M/s Assotech Sun Growth Abode LLP  
Flat No-203, Soumya Enclave F-15  
BJB Nagar  
Bhubaneswar

Sub: NOC for establishment of the unit of "Assotech Pride" dwelling unit over Plot No-274/9190, 276, 277/856, 277/8893, 279/10152, 279 others Khata No-412/1079, 412/1349 and others in Mouza- Rudrapur & Jayapur in favour of Assotech Sun Growth Abode LLP and others.


Ref: Your letter No Nil date- 18.12.19

Sir,

With reference to the above cited subject, it is to intimate you that, as the load requirement of aforesaid project is 10MVA (exceeding 1MVA) the power y release from GRIDCO and connectivity from OPTCL is a must to provide power supply to the above project. Bsidesthat, the take -up arrangement along with other infrastructure development will be borne by the applicant at his own cost in order to provide power supply to the above project. Full filling of the above criteria, CESU has no objection to provide power supply to the project "ASSOTECH PRIDE" over Plot No-274/9190, 276, 277/856, 277/8893, 279/10152, 279 others Khata No-412/1079, 412/1349 and others in Mouza- Rudrapur & Jayapur .

This is for your information and necessary action.

Yours faithfully,

  
Executive Engineer (Elect.)  
BED, Bhubaneswar

Cc to:

The SDO (Elect.) Rasulgarh Sub division for information.