

TPCODL

OFFICE OF THE EXECUTIVE ENGINEER (ELECT.)
KHORDHA ELECTRICAL DIVISION: KHORDHA

Date 18/2/2021

No.-TPCODL/KED/Tech./ 2015

To

M/S NBER Developers LLP,
C/o- Sri Chetan Kumar Tekriwala,
At- Godadharmanagar, Jatni, Khata No.- 106,
Plot No.- 343 & 343/367,
Mouza- Godadharmanagar, Dist- Khordha.

Sub: - Permission for construction of 11KV line with installation of S/S towards power supply to 10 KW load construction power at 11KV end for construction of S+4 storey Residential Apartment, At- Godadharmanagar, Jatni, Khata No.- 106, Plot No.- 343 & 343/367, Mouza- Godadharmanagar, Dist- Khordha under Electrical Section No.-II Jatni, on G.P.S. Tariff, under Deposit Work (on 6% Supervision charges).

Ref:- Approval letter No.- 339, Dt-10.02.2021 of Superintending Engineer (Elect.) Electrical Circle No.-II, BBSR

Sir,
With reference to the subject cited above, the permission is hereby accorded for construction of 11KV line with installation of S/S towards power supply to 10 KW load construction power at 11KV end for construction of S+4 storey Residential Apartment, At- Godadharmanagar, Jatni, Khata No.- 106, Plot No.- 343 & 343/367, Mouza- Godadharmanagar, Dist- Khordha under Electrical Section No.-II Jatni, on G.P.S. Tariff, under Deposit Work (on 6% Supervision charges) for execution of following works as per terms & condition mention below.

Details of Work

Sl. No.	Name of the Work	Scope of Work	Sanction Est. No.	Amount (Rs.)	Remarks
1	Power supply to 10 KW load at 11KV end for construction power, At- Godadharmanagar, Khata No.- 106, Plot No.- 343 & 343/367, Mouza- Godadharmanagar, Dist- Khordha under Electrical Section No.-II Jatni.	1. Installation of 25KVA, 11/4 KV pole mounted S/S - 1No. using 10mtr long 100x116mm R.S. Joist pole. 2. Construction of 11KV line 3Φ 3w using 10Mtr long 100x116mm R.S. Joist pole with 55mm ² Insulated Conductor - 0.02Km (1No. Span) with erection of 11KV structure pole using 10Mtr long 100x116mm R.S. Joist pole-1No. 3. Erection of 11KV intermediate pole using 10Mtr long 100x116mm R.S. Joist pole - 1No.	<u>KED/</u> <u>DEP(6%)</u> <u>/513/</u> <u>2020-21</u>	Rs.3,70,082.00(G) 1) Supervision Charges(6%) = Rs.20,948.00, 2) GST (18%) on 6% = Rs.3,771.00 & 3) Cess (1%) = Rs.3,700.00	1. Sl. No. 1 in scope of works is to be executed & maintained by party 2. Sl. No. 2 & 3 in the scope of works is to be executed by party & maintained by TPCODL under deposit work on 6% Supervision Charges.

Terms & condition:-

- You have to deposit Rs.20,948.00 (Rupees Twenty Thousand Nine Hundred Forty Eight) only towards 6% supervision charges, Rs.3,771.00 (Rupees Three Thousand Seven Hundred Seventy One) only towards 18% GST amount on 6% Supervision charges & Rs.3,700.00 (Rupees Three Thousand Seven Hundred) only towards 1% Cess charges as per the sanctioned estimate (Estimate No - KED/DEP(6%)/513/2020-21) sanctioned by Dy. General Manager (Elect.) K.E.D. Khordha & approved by Superintending Engineer (Elect.) Electrical Circle No.-II, TPCODL, BBSR (Copy of the estimate is enclosed for reference).
- You are requested to please deposit the 6% supervision charges, 18% GST on 6% Supervision Charges, 1% Cess Charges & security amount in shape of Bank Draft to drawn in favour of "TPCODL, KED, KHURDA" payable at Khurda. Further you are requested to deposit the GSTN certificate to this office at the time of deposit of GST amount.
- You have to produce the valid license of the Electrical Contractor before execution of the work.
- The materials used for construction purpose should confirm to REC/ISI specification. After procurement of materials to be used for construction of 11KV line, erection of 11KV intermediate pole and installation of Sub-station you have to send a request letter to the S.D.O.(Elect.) Jatni with the Xerox copy of the cash memo with "Test Certificate" & "Type Test" report of materials for verification and approval of the same.
- Prior to taking of work, the S.D.O (Elect.) Jatni and J.M. (Elect.) No.-II Jatni are to be intimated for route alignment work.
- The transformer should be star rated with minimum level of "No Load Losses" as specified by BEE. The manufacture should be advised accordingly to produce the certificate from BEE.

TP CENTRAL ODISHA DISTRIBUTION LIMITED
(A Tata Power and Odisha Government Joint Venture)
Corporate Office - IDCO Towers, 2nd Floor, Janpath, Bhubaneswar - 751022
www.tpcentralodisha.com